

GREATER HYDERABAD MUNICIPAL CORPORATION

ENFORCEMENT AND VIGILANCE DISASTER MANAGEMENT

**From
District Fire Officer
Fire Prevention Wing
GHMC,Hyderabad**

**To
IVY LEAGUE ACADEMY
Sy.No.396,Bommarasaipet Village,
Shamirpet Mandal,Medchal District**

Rc.No:112/DF0/EVDM/GHMC/2019, Dated:04/02/2019

Sub:- Greater Hyderabad Municipal Corporation-Enforcement and Vigilance Disaster Management Wing Fire No Objection Certificate not required for, **IVY LEAGUE ACADEMY Sy.No.396,Bommarasaipet Village,Shamirpet Mandal,Medchal District.** as per section 13 f Fire Service Act.

Ref:-2.Application of, **IVY LEAGUE ACADEMY Dated 4/02/2019.**

Section 13 (1) of Fire Service Act-Any person proposing to construct a building of more than 15 meters height for Commercial/ Business purpose, 18 meters and above height for Residential purpose, and buildings of Public congregation like schools, Cinema Halls, Function Halls, Religious Places, which are more than 500 Sq. meters in plot area or 6 meters and above in height shall apply to the Director General or any member of the service duly authorized by him in this behalf, before submission of such building plans to the authority or officer competent to approve the same under the relevant law, for the time being in force, for a no objection certificate along with such fee as may be prescribed.

In view of the above since the above mentioned for **IVY LEAGUE ACADEMY Sy.No.396,Bommarasaipet Village,Shamirpet Mandal,Medchal District** teach Building is in plot area less than 500 Sq. meter (plot area measuring 400 Sq.meters) and height less than 6 meters as per reference cited. Fire "No Objection Certificate" is not required.

Yours faithfully,

Place : Hyderabad
Date: 07/02/2019

Sankar Prasad
District Fire Officer
District Fire Officer
Ranga Reddy District
Holding (FAC) Regional Fire Officer
Central Region, Telangana, Hyderabad

For **IVY LEAGUE ACADEMY.**

[Signature]
Correspondent.

PRINCIPAL

Ivy League Academy